



# ICAO ENGINE EXHAUST EMISSIONS DATA SHEET

## SUBSONIC ENGINES

ENGINE IDENTIFICATION: CF34-8E5A2  
UNIQUE ID NUMBER: 01P08GE199  
COMBUSTOR: LEC  
ENGINE TYPE: TF

BYPASS RATIO: 5.1  
PRESSURE RATIO ( $\pi_{00}$ ): 24.8  
RATED THRUST ( $F_{00}$ ) (kN): 64.5

### REGULATORY DATA

CHARACTERISTIC VALUE:	HC	CO	NO <sub>x</sub>	SMOKE NUMBER
D <sub>p</sub> /F <sub>00</sub> (g/kN) or SN	0.4	38.0	46.1	22.2
AS % OF ORIGINAL LIMIT	2.2	32.2	51.4	83.3
AS % OF CAEP/2 LIMIT (NO <sub>x</sub> )			64.2	
AS % OF CAEP/4 LIMIT (NO <sub>x</sub> )			72.2	
AS % OF CAEP/6 LIMIT (NO <sub>x</sub> )			77.4	
AS % OF CAEP/8 LIMIT (NO <sub>x</sub> )			87.4	

For non-volatile particulate matter (nvPM) emissions, please refer to the ICAO Engine nvPM Emissions Data Sheet.

### DATA STATUS

- PRE-REGULATION  
x CERTIFICATION  
- REVISED (SEE REMARKS)

### TEST ENGINE STATUS

x NEWLY MANUFACTURED ENGINES  
- DEDICATED ENGINES TO PRODUCTION STANDARD  
- OTHER (SEE REMARKS)

### EMISSIONS STATUS

x DATA CORRECTED TO REFERENCE  
(ANNEX 16 VOLUME II)

### CURRENT ENGINE STATUS

(IN PRODUCTION, IN SERVICE UNLESS OTHERWISE NOTED)

x OUT OF PRODUCTION (DATE: - )  
- OUT OF SERVICE (DATE: - )

### MEASURED DATA

MODE	POWER SETTING (%F <sub>00</sub> )	TIME (minutes)	FUEL FLOW (kg/s)	HC	CO	NO <sub>x</sub>	SMOKE NUMBER
TAKE-OFF	100	0.7	0.721	0.02	0.77	16.71	17.3
CLIMB OUT	85	2.2	0.586	0.02	0.57	13.52	4.4
APPROACH	30	4.0	0.193	0.06	3.92	11.09	0.0
IDLE	7	26.0	0.067	0.12	16.71	4.76	0.0
LTO TOTAL FUEL (kg) or EMISSIONS (g)			259	18	1999	2565	-
NUMBER OF ENGINES				1	1	1	1
NUMBER OF TESTS				3	3	3	3
AVERAGE D <sub>p</sub> /F <sub>00</sub> (g/kN) or AVERAGE SN (MAX)				0.3	31.0	39.8	17.3
SIGMA (D <sub>p</sub> /F <sub>00</sub> in g/kN, or SN)							
RANGE (D <sub>p</sub> /F <sub>00</sub> in g/kN, or SN)							

### ACCESSORY LOADS

POWER EXTRACTION 0 (kW)  
STAGE BLEED 0 (% CORE FLOW)

AT - POWER SETTINGS  
AT - POWER SETTINGS

### ATMOSPHERIC CONDITIONS

BAROMETER (kPa)	97.1-98.1
TEMPERATURE (K)	284-292
ABS HUMIDITY (kg/kg)	0.0047-0.00727

### FUEL

SPEC	Jet A
H/C	1.94
AROM (%)	18

MANUFACTURER: General Electric Company  
TEST ORGANIZATION: CF6 Eval Engineering  
TEST LOCATION: PTO Site 3B Peebles  
TEST DATES: 27/01/2002-28/01/2002

### REMARKS

1. Ref. GE REPORT R2001AE078
2. Engine S/N 193111
3. Data corrected per ICAO Annex 16, Vol 2, Part III, Appendix 3

Compliance with Fuel Venting requirements:

- ('x' if complies, 'PR' if pre-regulation, '-' if information is not available)