



ICAO ENGINE nvPM EMISSIONS DATA SHEET

SUBSONIC ENGINES

ENGINE IDENTIFICATION:	PW1519G	BYPASS RATIO (-):	11.6
UNIQUE ID NUMBER:	01P20PW186	PRESSURE RATIO π_{co} (-):	32.3
COMBUSTOR:	TALON X, Block-C		
ENGINE TYPE:	TF	RATED OUTPUT F_{oo} (kN):	88.0

REGULATORY DATA

CHARACTERISTIC VALUES:	LTO _{mass} /F _{oo} (mg/kN)	LTO _{num} /F _{oo} (particles/kN)	NVPM MASS CONCENTRATION ($\mu\text{g}/\text{m}^3$)
LTO/F _{oo} AND MAX nvPM _{mass}	6.7	3.86E+14	190
AS % OF CAEP/10 LIMIT	-	-	2.7
AS % OF CAEP/11 LIMIT (InP)	0.3	2.3	
AS % OF CAEP/11 LIMIT (NT)	1.0	5.0	

MEASURED DATA

MODE	POWER SETTING (%F _{oo})	TIME minutes	FUEL FLOW kg/s	EMISSIONS INDICES*		NVPM MASS CONCENTRATION PEAK nvPM _{mass} ($\mu\text{g}/\text{m}^3$)
				EI _{mass} (mg/kg)	EI _{num} (particles/kg)	
TAKE-OFF	100	0.7	0.623	6.3	1.77E+14	
CLIMB OUT	85	2.2	0.520	2.5	1.18E+14	
APPROACH	30	4.0	0.191	0.1	1.82E+13	
IDLE	7	26.0	0.067	0.8	1.04E+14	
LTO TOTAL (kg, mg, number of particles)			246	425	2.44E+16	-
NUMBER OF ENGINES				1	1	1
NUMBER OF TESTS				3	3	3
AVERAGE LTO/F _{oo} VALUES (mg/kN, particles/kN)				4.8	2.78E+14	-
MAX EI VALUES (mg/kg, particles/kg) AND MAX MASS CONC. ($\mu\text{g}/\text{m}^3$)				6.3	1.77E+14	147

* Emissions Indices are corrected for thermophoretic loss and fuel hydrogen content

DATA FOR EMISSIONS INVENTORIES (ESTIMATIONS FOR ENGINE EXIT PLANE VALUES)

MODE	POWER SETTING (%F _{oo})	CORRECTED EMISSIONS INDICES	
		EI _{mass_sl} (mg/kg)	EI _{num_sl} (particles/kg)
TAKE-OFF	100	8.8	8.99E+14
CLIMB OUT	85	4.0	7.73E+14
APPROACH	30	0.2	8.66E+13
IDLE	7	0.9	8.42E+14

AMBIENT CONDITIONS

AMBIENT CONDITIONS			FUEL	
	From	To		
BAROMETER (kPa)	102.0	103.3	HEAT OF COMBUSTION (MJ/kg)	43.21
TEMPERATURE (K)	272.0	278.1	HYDROGEN CONTENT (%mass)	13.98
HUMIDITY (kg water/kg dry air)	0.0012	0.0022	AROMATICS CONTENT (%vol)	18.1
			NAPHTHALENE CONTENT (%vol)	0.78
			SULPHUR CONTENT (ppm by mass)	553

MANUFACTURER:	Pratt & Whitney
TEST ORGANIZATION:	Pratt & Whitney
TEST LOCATION:	Mirabel Aerospace Centre, Quebec, Canada
TEST DATES:	25/03/2018-26/03/2018

REMARKS

1. Data from certification report PWA-12245-02
2. Block C combustor
3. nvPM levels in accordance with Annex 16 Vol. II, Chapter 4, Appendix 7 and Appendix 8.

**** DATA SUPERSEDED ****

SEE FOLLOWING UID FOR REVISED DATA:

04P20PW199