



# ICAO ENGINE EXHAUST EMISSIONS DATA SHEET

## SUBSONIC ENGINES

ENGINE IDENTIFICATION: CF6-80C2B5F BYPASS RATIO: 5.1  
 UNIQUE ID NUMBER: 3GE057 PRESSURE RATIO ( $\pi_{00}$ ): 32.8  
 COMBUSTOR: 1862M39  
 ENGINE TYPE: TF RATED THRUST ( $F_{00}$ ) (kN): 272.5

REGULATORY DATA **\*\* DATA SUPERSEDED \*\*** SEE FOLLOWING UID FOR REVISED DATA: **01P03GE187**

CHARACTERISTIC VALUE:	HC	CO	NO <sub>x</sub>	SMOKE NUMBER
D <sub>p</sub> /F <sub>00</sub> (g/kN) or SN	2.2	24.8	53.0	8.7
AS % OF ORIGINAL LIMIT	11.2	21.0	50.2	48.4
AS % OF CAEP/2 LIMIT (NO <sub>x</sub> )			62.7	
AS % OF CAEP/4 LIMIT (NO <sub>x</sub> )			73.0	
AS % OF CAEP/6 LIMIT (NO <sub>x</sub> )			82.0	
AS % OF CAEP/8 LIMIT (NO <sub>x</sub> )			95.1	

### DATA STATUS

- PRE-REGULATION  
 x CERTIFICATION  
 - REVISED (SEE REMARKS)

### TEST ENGINE STATUS

x NEWLY MANUFACTURED ENGINES  
 - DEDICATED ENGINES TO PRODUCTION STANDARD  
 - OTHER (SEE REMARKS)

### EMISSIONS STATUS

x DATA CORRECTED TO REFERENCE  
 (ANNEX 16 VOLUME II)

### CURRENT ENGINE STATUS

(IN PRODUCTION, IN SERVICE UNLESS OTHERWISE NOTED)  
 - OUT OF PRODUCTION (DATE: - )  
 - OUT OF SERVICE (DATE: - )

### MEASURED DATA

MODE	POWER SETTING (%F <sub>00</sub> )	TIME (minutes)	FUEL FLOW (kg/s)	EMISSIONS INDICES (g/kg)			SMOKE NUMBER
				HC	CO	NO <sub>x</sub>	
TAKE-OFF	100	0.7	2.685	0.05	0.05	28.58	7.4
CLIMB OUT	85	2.2	2.162	0.05	0.04	21.76	5.2
APPROACH	30	4.0	0.697	0.11	1.83	12.74	0.0
IDLE	7	26.0	0.206	1.31	17.45	4.91	0.0
LTO TOTAL FUEL (kg) or EMISSIONS (g)			887	459	5931	13142	-
NUMBER OF ENGINES				2	2	2	2
NUMBER OF TESTS				4	4	4	4
AVERAGE D <sub>p</sub> /F <sub>00</sub> (g/kN) or AVERAGE SN (MAX)				1.7	21.8	48.2	7.4
SIGMA (D <sub>p</sub> /F <sub>00</sub> in g/kN, or SN)							
RANGE (D <sub>p</sub> /F <sub>00</sub> in g/kN, or SN)							

### ACCESSORY LOADS

POWER EXTRACTION 0 (kW) AT - POWER SETTINGS  
 STAGE BLEED 0 (% CORE FLOW) AT - POWER SETTINGS

### ATMOSPHERIC CONDITIONS

BAROMETER (kPa)	97.6-98.2
TEMPERATURE (K)	279-293
ABS HUMIDITY (kg/kg)	0.0046-0.0074

### FUEL

SPEC	Jet A
H/C	1.94
AROM (%)	15.3

MANUFACTURER: General Electric Company  
 TEST ORGANIZATION: CF6 Eval Engineering  
 TEST LOCATION: Site IIIB, PTO, Peebles, Ohio  
 TEST DATES: 13/01/1995-17/01/1995

### NO<sub>x</sub> REGULATION PARAGRAPH

	2.3.2 c) (CAEP/4)
	2.3.2 d) (CAEP/6)
x	2.3.2 e) (CAEP/8)

### REMARKS

- GE Report TM95-17.
- Engine S/N 704/223 & 704/234
- 1862M39 combustor
- Certification in accordance with Part III, Chapter 2, of Amendment 7 of ICAO Annex 16 Vol. II.
- NO<sub>x</sub> levels in accordance with Part III, Chapter 2, 2.3.2 e)

Compliance with Fuel Venting requirements: - ('x' if complies, 'PR' if pre-regulation, '-' if information is not available)