



# ICAO ENGINE EXHAUST EMISSIONS DATA SHEET

## SUBSONIC ENGINES

ENGINE IDENTIFICATION: CF6-80C2B2      BYPASS RATIO: 5.1  
 UNIQUE ID NUMBER: 1GE025      PRESSURE RATIO ( $\pi_{00}$ ): 27.7  
 COMBUSTOR:  
 ENGINE TYPE: TF      RATED THRUST ( $F_{00}$ ) (kN): 231.1

### REGULATORY DATA

CHARACTERISTIC VALUE:	HC	CO	NO <sub>x</sub>	SMOKE NUMBER
D <sub>p</sub> /F <sub>00</sub> (g/kN) or SN	19.2	73.7	41.9	6.8
AS % OF ORIGINAL LIMIT	97.9	62.4	43.9	36.1
AS % OF CAEP/2 LIMIT (NO <sub>x</sub> )			54.8	
AS % OF CAEP/4 LIMIT (NO <sub>x</sub> )			66.1	
AS % OF CAEP/6 LIMIT (NO <sub>x</sub> )			75.1	
AS % OF CAEP/8 LIMIT (NO <sub>x</sub> )			89.3	

### DATA STATUS

- PRE-REGULATION  
 x CERTIFICATION  
 - REVISED (SEE REMARKS)

### TEST ENGINE STATUS

x NEWLY MANUFACTURED ENGINES  
 - DEDICATED ENGINES TO PRODUCTION STANDARD  
 - OTHER (SEE REMARKS)

### EMISSIONS STATUS

x DATA CORRECTED TO REFERENCE  
 (ANNEX 16 VOLUME II)

### CURRENT ENGINE STATUS

(IN PRODUCTION, IN SERVICE UNLESS OTHERWISE NOTED)  
 x OUT OF PRODUCTION (DATE: - )  
 - OUT OF SERVICE (DATE: - )

### MEASURED DATA

MODE	POWER SETTING (%F <sub>00</sub> )	TIME (minutes)	FUEL FLOW (kg/s)	EMISSIONS INDICES (g/kg)			SMOKE NUMBER
				HC	CO	NO <sub>x</sub>	
TAKE-OFF	100	0.7	2.131	0.08	0.57	23.89	5.8
CLIMB OUT	85	2.2	1.761	0.10	0.55	18.65	3.9
APPROACH	30	4.0	0.577	0.22	2.65	8.77	2.4
IDLE	7	26.0	0.192	11.17	48.02	3.70	3.1
LTO TOTAL FUEL (kg) or EMISSIONS (g)			760	3407	14929	8796	-
NUMBER OF ENGINES				2	2	2	2
NUMBER OF TESTS				3	3	3	3
AVERAGE D <sub>p</sub> /F <sub>00</sub> (g/kN) or AVERAGE SN (MAX)				14.8	64.7	38.1	5.8
SIGMA (D <sub>p</sub> /F <sub>00</sub> in g/kN, or SN)				1.3	2.9	1.8	1.0
RANGE (D <sub>p</sub> /F <sub>00</sub> in g/kN, or SN)				13.68-16.01	62.12-67.28	36.7-40.37	4.6-6.3

### ACCESSORY LOADS

POWER EXTRACTION 0 (kW) AT - POWER SETTINGS  
 STAGE BLEED 0 (% CORE FLOW) AT - POWER SETTINGS

### ATMOSPHERIC CONDITIONS

BAROMETER (kPa)	97.4-97.8
TEMPERATURE (K)	287-296
ABS HUMIDITY (kg/kg)	0.0084-0.014

### FUEL

SPEC	Jet A
H/C	1.94
AROM (%)	15.3

MANUFACTURER: General Electric Company  
 TEST ORGANIZATION: CF6 Eval Engineering  
 TEST LOCATION: Site IIIC, PTO, Peebles, Ohio  
 TEST DATES: 29/05/1985-03/06/1985

### REMARKS

1. Ref GE Report R86AEB589.
2. Engine S/N's 690105 and 690005/2.

Compliance with Fuel Venting requirements: - ('x' if complies, 'PR' if pre-regulation, '-' if information is not available)